# IEA Wind Task 51

#### IEA Wind Recommended Practice for the Implementation of Renewable Energy Forecasting Solutions



IEA Wind Recommended Practice for the Implementation of Renewable Energy Forecasting Solutions



# Hands-on examples for the use of the guideline



Corinna Möhrlen John W. Zack Gregor Giebel

Mathias Blicher Bjerregaard







# Overview

- Background: IEA Wind Recommended Practice (RP) for the Implementation of Renewable Energy Forecasting Solutions
  - 0 What it is
  - <sup>o</sup> Where to get it
- Use Case Examples based on Recommendations
  - Wind speed evaluation at a Danish Coastal Site
  - Wind power evaluation at a substation in Ireland
  - Meteorological sensor performance assessment at a site in the German Bight (discussed in the paper not included in this presentation)

#### IEA Wind Recommended Practice for the Implementation of Renewable Energy Forecasting Solutions: Set of 4 Parts



#### Video Introduction

Introduction: https://www.youtube.com/watch?v=XVO37hLE03M



# IEA Wind Recommended Practice Book

#### <sup>∿</sup>Note

#### **Elsevier Book**

https://www.elsevier.com/books/iea-wind-re commended-practice-for-the-implementatio n-of-renewable-energy-forecasting-solution s/mohrlen/978-0-443-18681-3

#### **Online OpenAccess:**

https://www.sciencedirect.com/book/9780443186 813/iea-wind-recommended-practice-for-the-impl ementation-of-renewable-energy-forecasting-sol utions

IEA Wind Task 51 Information iea-wind.org  $\rightarrow$  Task 51  $\rightarrow$ Publications  $\rightarrow$ 

**Recommended Practice** 



IEA Wind Recommended Practice for the Implementation of Renewable Energy Forecasting Solutions



Corinna Möhrlen John W. Zack Gregor Giebel iea wind

# IEA Wind Recommended Practice for the Implementation of Renewable Energy Forecast Solutions

#### **Application Areas for the Recommendations**

#### **1. System Operation, Balancing and Trading**

- Situational awareness in critical weather events
- High-Speed Shutdown events
- Grid related down-regulation or curtailments
- Short-term forecasting with updates from measurements
- Intra-day power plant balancing

#### 2. Wind Turbine, Wind Farm and Solar Plant Operation and Monitoring

- Wind turbine and Power Plant Control
- Condition Monitoring

## **Companion Evaluation Software: "WE-validate-prob" Assessment of forecasts with an R-package code**





# Recommendation: Establish an Evaluation Framework Key Components

(1) Choose a time period likely to (1) the forecast produce a representative sample application Specify the **Define the** of relevant weather patterns (2) the key forecast time forecast evaluation (2) Choose a sufficient and wellframes framework sample defined evaluation time frame (3) a ranking of the (e.g. 3 months, 1 year, ...) importance of forecast performance attributes (1) visual inspection (2) use of more specific metrics: SDE, SDBIAS, StDev, VAR, CORR (1) Strategy to deal with **Define set of** (3) use of histogram or box plot missing or erroneous data Quality for evaluation of outliers & forecasts error control & (4) use of contingency tables for (2) Specify evaluation evaluation delivery specific event analysis criteria on delivery approaches performance (5) use of improvement scores performance relative to a relevant reference

forecast



# Example 1: Evaluation of Wind Speed at a Danish Coastal Site

Aim: Verify the high resolution versus the low-resolution setup of an ensemble prediction system and evaluate improvement versus cost Specify the Define the forecast evaluation framework sample Define set of Ouality error control & evaluation deliverv approaches performance R Package

WE-validate-prob

**Definition of the Sample:** Danish synoptic meteorological site: South-west Funen "Assens"

- High-Resolution (HR): 5km grid cells with 60 vertical levels
- Low resolution (LR): 15km grid cells with 32 vertical levels

#### **Evaluation Approach:**

- CRPS
- CRPS lead-time dependency
- Reliability Diagram

# **Evaluation of Wind Speed at a Danish coastal site**

Assessment of a high-resolution versus low resolution ensemble system

Forecast	CRPS	Improvement to
Туре		Reference [%]
Reference	1.6635	
Lead-time	6-11h	
HR	1.140	-31.5
LR	1.159	-30.3
Lead-time	0-48h	
HR	1.1236	-32.5
LR	1.0925	-34.3



Result from Test 1: High-resolution setup has only value in the first 12 hours

Conclusion: High-resolution setup can be complementary in the intra-day...

## **Evaluation of Wind Speed at a Danish coastal site** Assessment of a high-resolution versus low resolution ensemble system

Reliability is the degree to which the forecasted probabilities are in agreement with the outcome frequencies

HR-setup

iea wind



**Result:** tendency to lie on top of the diagonal for LR; Hr only in lower bins  $\rightarrow$  indicates a negative BIAS and or a slight mis-calibration **Conclusion:** HR setup has a better balance between resolution and calibration, staying mostly within the blue 90% consistency band.

**Explanation of Score: Reliability Diagram** <u>X-axis:</u> forecasted probabilities Y-axis: conditional event probabilities (CEP)  $\rightarrow$  the frequency of observed events given the specific forecast probability

#### **Evaluation Criteria:**

- Threshold: 5 (a minimum of 5 "positives" needed for an event)
- Forecast horizon: 6-11 hours
- Change in wind speed: ٠ 3m/s over a 3 hour window.



R

## **Example 2: Wind Power Evaluation at a** Substation in the North-west of Ireland



Package

WE-validate-prob



#### **Definition of the Sample:**

Sub station in North-west of Ireland: A number of wind farms are feeding into the substation (wind farm cluster). Forecast type:

#### **Ramp forecasts**

- High-Resolution (HR): 5km grid cells with 60 vertical levels
- Low resolution (LR): 15km grid cells with 32 vertical levels

### **Evaluation Approach:**

- CRPS
- **Brier Score**
- ROC

Wind Power Evaluation at a Substation in the North-west of Ireland Probabilistic Forecast Assessment of Ramping Events: CRPS & Brier Scores

#### **CRPS** score

overall performance of prob. forecast

Forecast	CRPS	CRPS	12
	[MW]	[% inst	. cap]
HR	10.5	5.8	
LR	10.9	6.0	No
Reference	20.6	11.5	significance

#### BRIER score

overall accuracy of a probabilistic *event* forecast

20MW	30MW	40MW	60MW
1hour	3 hours	3 hours	3 hours
0.0501	0.089	0.0513	0.021
0.0459	0.084	0.0464	0.018
0.0043	0.0053	0.0049	0.0028
	20MW 1hour 0.0501 0.0459 0.0043	20MW30MW1hour3 hours0.05010.0890.04590.0840.00430.0053	20MW30MW40MW1hour3 hours3 hours0.05010.0890.05130.04590.0840.04640.00430.00530.0049



Large sensitivity to event choice!

#### **Explanation of the score:**

- CRPS is the probabilistic <u>analogue to the Mean</u> <u>absolute error (MAE)</u> for a deterministic forecast.
- Lower CRPS values indicate smaller error and therefore better performance.
- CRPS scores for each forecast over the 3-month test period

Explanation of the score:

- BS is the probabilistic <u>analogue to mean squared error</u> (<u>MSE/RMSE</u>) of deterministic forecast
- BS measures the mean squared difference (MSE/RMSE) between the forecasted probability (e.g., 0 to 1) and the actual outcome (e.g., 0 or 1).
- The BS values range between 0 and 1 with lower values indicating better performance.

Wind Power Evaluation at a Substation in the North-west of Ireland Probabilistic Forecast Assessment of Ramping Events: Brier Score Decomposition

٠

#### **Decomposition of BRIER Scores**

Fore-	MS	CAL	DSC	UNC
cast			(RES)	
Limit:	30MW/3h			
HR	0.0892	0.0105	0.0274	0.106
LR	0.0839	0.0062	0.0283	0.106
Limit:	40MW/3h	$\sim$		
HR	0.0513	0.0074	0.0153	0.0592
LR	0.0464	0.0029	0.0157	0.0592
Limit:	60MW/3h	$\smile$		
HR	0.0210	0.0018	0.0024	0.0217
LR	0.0182	0.0010	0.0045	0.0217
Limit:	20MW/1h			
HR	0.0501	0.00494	0.00457	0.0498
LR	0.0459	0.00248	0.00639	0.0498

**Explanation of the Scores:** 

- Mean Score (MS) measure the overall predictive event performance
- **Calibration/reliability (CAL)**: measures the agreement of forecasted probability with frequency of event occurrence given the forecasted probability (conditional event probability)
- **Discrimination/resolution (DSC/RES)**: measures the ability of forecasts to correctly distinguish differences in probabilities among the cases.
- → <u>higher values</u> contribute to lower BS, i.e. indicate <u>better performance</u>.
  Uncertainty (UNC): measures inherent uncertainty in the event and is
- related to the event frequency in the sample.

 $\rightarrow$  lower values contribute to lower BS, max. UNC for 50% events in sample

**Result:** The difference between HR and LR insignificant overall (MS), but quite significant for some components and sensitive to the thresholds and classifiers: the calibration (CAL) in the 40MW/3h class and the discrimination (DSC) in the 60MW/3h class is significantly better for the LR setup...

**Conclusion:** Decomposition of the Brier score is important, as it reveals differences in the forecast's skill related to distinguish events and to match occurrence with probabilities.

# Wind Power Evaluation at a Substation in the North-west of Ireland Probabilistic Forecast Assessment of Ramping Events: **Reliability Diagram**

**Evaluation Criteria:** <u>Threshold</u>: 5 - <u>Forecast horizon</u>: 6-11 hours - <u>Change:</u> 30MW over a 3 hour window.



Explanation of Plots: X-axis: forecasted probabilities Y-axis: conditional event probabilities (CEP)  $\rightarrow$ frequency of observed events given the specific forecast probability Band: 90% consistency band

**Result:** tendency to lie on top the diagonal for HR; LR tendency to lie below diagonal

→ indicates a negative BIAS for LR and positive BIAS for HR ... and/or a slight mis-calibration

**Conclusion:** LR setup seems to be in better balance between resolution and calibration, staying mostly within the blue 90% consistency band – consistent with Brier score decomposition results....

### Wind Power Evaluation at a substation in the north-west of Ireland Probabilistic Forecast Assessment of forecasted Ramping Events: Reliability Diagram

#### Demonstration of threshold selection sensitivity







#### **Evaluation of Wind Power at a substation in north-west of Ireland** Probabilistic Forecast Assessment of Ramping Events: **Continency table**

#### Contingency table + HitRate (HR) and False Alarm rate (FAR)

Fore-	Hits	Misses	False	Correct	HR	FAR
cast			Alarms	Neg.		
Limit:	30MW	window:	3h			
HR	149	145	153	1990	0.507	0.071
LR	204	90	393	1750	0.694	0.183
Limit:	40MW	window:	3h			
HR	82	72	91	2192	0.532	0.04
LR	112	42	262	2021	0.727	0.115
Limit:	60MW	window:	3h			
HR	10	44	31	2352	0.185	0.013
LR	30	24	102	2281	0.556	0.043
Limit:	20MW	window:	1h			
HR	37	91	101	2208	0.289	0.044
LR	74	54	302	2007	0.578	0.131

#### <u>Result:</u>

LR forecasts have much higher number of "hits" LR forecasts have much more "false alarms" most extreme example of this pattern is for the 60MW/3hr threshold **Explanation of the Score:** The Contingency table lists: absolute number of "hits", "misses", "false alarms" and "correct negatives" in the forecast sample lists the "hit rate" (HiR)  $\rightarrow$  the hits per total number of forecasts "false alarm rate" (FAR)  $\rightarrow$  the false alarms per total number of forecasts.

# → requires to look into costs for misses versus false alarms...

#### **Conclusion:**



Beware of the threshold selection sensitivity in selection process and when analysing and evaluating the results Fair evaluation comparison requires to provide the thresholds in advance

## Wind Power Evaluation at a substation in the north-west of Ireland Probabilistic Forecast Assessment of forecasted Ramping Events: ROC Curve

Receiver Operating Characteristics (ROC) curve measures the ability to discriminate between events and nonevents and depicts the performance of forecasts at different probability thresholds



iea wind

#### "Area Under the Curve" (AUC) for different ramping limits and time windows



#### **Result:**

0.8

9.0

0.4

0.2

Both forecast setups perform OK with a AUC > 0.7.

- Slightly better, but little
- (insignificant) difference in
- the AUC scores for the LR
- forecasts

Explanation of the Score:

- The ROC curve ascends vertically at FAR=0.0 and horizontally at a sensitivity (hit rate) value of 1.0
- The color scale indicates classification thresholds yielding the points on the curve
- AUC= 1.0 for every forecast is a hit and no false ٠ alarms, 0.5 for random classifiers, i.e. forecasts with no skill (diagonal in graph)

**Conclusion:** the ROC curve confirms the results from the Brier Scores and indicates that the difference is not due to a mis-calibration.

### Wind Power Evaluation at a substation in the north-west of Ireland Probabilistic Forecast Assessment of forecasted Ramping Events: ROC Curve



**Evaluation of Wind Power at a Substation in North-west of Ireland** 

ieq wind Probabilistic Forecast Assessment of Ramping Events: **Composite Performance Metric** 

Score	HR	LR	IF weight	HR Final Score	LR Final Score
CRPS	1	0	3	3	0
CRPS leadtime	1	0	4	4	0
BrierScores	0	1	2	0	2
Hit Rate	0	1	1	0	1
False Alarm rate	1	0	2	2	0
Mean Score	0	1	1	0	1
CAL	0	1	1	0	1
DSC	0	1	1	0	1
UNC	-		1	-	-
AUC	0	1	1	0	1
SUM	3	6		9	7
					<u>&gt;</u>

Assessment of the Forecast Error Scores:

- For the raw (unweighted) scoring, the high-resolution (HR) setup has a lower composite score (is "worse") than the low resolution (LR) setup
- If weights are applied according to the importance of each error metric for this application, the HR has a higher score indicating it may be a better choice for this application







# **Lessons Learned and Take-away**

Forecast Evaluation is subjective... remember the 4 cornerstones for meaningful evaluation



# **THANK YOU FOR YOUR ATTENTION**



#### Follow us:

Project webpage: http://iea-wind.org/task51

Publications: <u>https://iea-wind.org/task51/task51-publications</u>

RP-page: <u>https://iea-wind.org/task51/task51-publications/task51-recommended-practices/</u>

Contact us...

#### **Presenter:**

Dr. John W. Zack WP2 Leader MESO, Inc, USA jzack@meso.com



### Co-authors:

Dr. Corinna Möhrlen WP3 Leader WEPROG, DE & DK



<u>Dr. Mathias Blicher B.</u> <u>DTU Compute</u> <u>Denmark</u>

DTU

Dr. Gregor Giebel Operating Agent DTU Wind, Denmark grgi@dtu.dk

DTU